

PRECAUTIONARY DRINKING WATER WARNING DO NOT DRINK THE WATER USE BOTTLED WATER

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

On January 9, 2019 Clifton E Lawrence School experienced a loss of water pressure due to the well pump failing.

What should I do?

- **DO NOT DRINK THE WATER. Bottled water will be provided in common areas, hallways, and classrooms.**
- There is nothing you need to do. However, if you have specific health concerns, consult your doctor.
- If you have a severely compromised immune system, have an infant, are pregnant, or are elderly, you may be at increased risk and should seek advice from your health care providers about drinking this water.

What is being done?

Clifton E. Lawrence has repaired the blown fuse which powers the well pump, and normal water pressure was restored yesterday. 3 distribution samples will be collected on 1/10/19 to determine if the water quality is satisfactory.

For more information please contact Frank Pietrowski, Director of Facilities for the Clifton E. Lawrence School at 973-875-3175.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Clifton E. Lawrence School

ID#: NJ1924318

Date distributed: 1/10/19